

TECHNICAL SITE SPECS | 400 76TH STREET SW SUITE 12 BYRON CENTER, MI 49315

LOCATION AND SITE INFORMATION	
Address	400 76th Street SW Suite 12 Byron Center, MI 49315
Colocation Space	3,500 sq. ft.
Floor Type	Slab
Loading Area	Street Level
SITE STRUCTURE	
Year Built	Retrofitted in 2012; originally built in 2009
Number of Floors	1
Structure Type	Structural Steel, Brick Trim
Exterior Type	Steel
Ceiling Clearance	10 ft.
In Flood Plain	No
SITE UTILITY	
Electricity Provider	Consumers
Available Utility Power	1.2 mw
COMMUNICATION	
NPA-NXX	616-878
# of Entrance Vaults	2
Redundant Paths	Carrier Dependant

FIBER PROVIDERS		
123Net	ACD	
AT&T	Lynx Network Group	
Comcast	US Signal	
UPSTREAM PROVIDERS		
Level (3) - 10G (Southfield, MI)	Savvis - 10G (Ashburn, VA)	
Cogent - 10G (Southfield, MI)	GTT - 10G (Chicago, IL)	
Comcast - 10G (Chicago, IL)	TeliaSonera - 10G (Chicago, IL)	
CenturyLink - 10G (Chicago, IL)	Verizon - 10G (Chicago, IL)	
PEERING LOCATIONS		
DET-IX (Detroit, MI)	Equinix Chicago (Chicago, IL)	Equinix Ashburn (Ashburn, VA)
ENVIRONMENTAL CONTROL		
CEU Quantity	(2) Outside pad units	
Total BTU	100 Tons	
Cooling Type	Direct Expansion (DX)	
Redundant	Yes, n+1	

AC POWER	
UPS	(1) Toshiba (2) Liebert Units
Sizes	(2) 100kVa, 500kVa
Redundancy	n+1
Harmonic Filters	Yes
Battery Type	GNB
Battery Life at Full Load	10 minutes
Generator	(1) Caterpillar, (1) Detroit
Generator Sizes	750kVa, 500kVa
Generator Fuel	(2) Diesel; priority fuel agreement
Remotely Monitored	Yes
SECURITY	
CCTV	Yes, Exterior/Interior
CCTV Recorder	Up to 90 Days
Gated Facility	Yes
Card Access	HID Proximity Card
Access Control	Keypad access to site
FIRE PROTECTION	
Wet or Pre-Action	Fire ECARO -25 Gas
Number of Zones	2
Smoke/Heat Detection	Yes
Remotely Monitored	Yes